Non Domestic
Gas Safety Record

This inspection is for gas safety purposes only in accordance with Gas Safety (Installation and Use) Regulations. Flues were inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the Flue integrity, construction and lining has not been carried out.

Form Serial Number: FRM/M02832

Registered Business Details: GAS SAFE NO:

Gas Operative : Chris Roberts **5804903**

Name : Horsfield Building Service Engineers Ltd

Address : Horsfield Place, Rough Hey Road ,
PRESTON, Lancashire

PostCode : PR2 5AR Telephone : 01772 654402

Job Address: Contact :

Name : New Longton Village Hall

Address : Mossway, New Longton
Preston, Lancashire, England

PostCode : PR4 4ZQ Telephone :

URN : Mike Taylor

Client Landlord's Details:

Name : New Longton Village Hall

Address : Management Committee, C/O 2 Mossway New Longton PR4 4ZQ
Boundary Close, New Longton,

PostCode : PR4 4YD Telephone : +441772616119

Rented Accommodation : No No of appliance tested : 2

Visual check to ensure burner pressure + FGAS test points have been replaced? Yes

Additional Work Carried Out:

PRV Lift Pressure Recorded at: N/A

Appliance Details / Inspection Details

	Location	Type	Make	Model	Landlords Appliance	Appliance Inspected	Flue Type	Operating Pressure	Heat Input	Safety Device(s) Correct Operation	Ventilation Provision Satisfactory	Visual Condition of Flue	Termination Satisfactory	Flue Performance Check	High Combustion Reading: CO PPM	High Combustion Reading: CO2 %	High Combustion Reading: CO/ CO2 Ratio	Low Combustion Reading: CO PPM	Low Combustion Reading: CO2 %	Low Combustion Reading: CO/ CO2 Ratio	Spillage Test	Appliance Serviced	Safe To Use
1	Plant Room	Boiler	Atag	XL110 Burner A	Yes	Yes	OF	20 Mbars	N/A	Yes	Yes	Pass	Pass	Pass	30	9.1	0.0003	19	8.1	0.0002	N/A	Yes	Yes
2	Plant Room	Boiler	Atag	XL110 Burner B	Yes	Yes	OF	20 Mbars	N/A	Yes	Yes	Pass	Pass	Pass	35	9.2	0.0003	21	8.4	0.0002	N/A	Yes	Yes
3																							
4																							

Defect Details

	Appliance #	Defect Identified	Remedial Action	Warning Label Fitted	Warning Issued	Warning Note Serial No
1						
2						
3						

Smoke/ CO Alarm Details

	Location	Type	Approved Alarm Fitted	Alarm Expiry	Testing of Alarm Satisfactory	Battery/ Hard wired	Replacement Required
1							
2							

Gas installation pipework satisfactory visual inspection	Yes
Emergency control accessible	Yes
Satisfactory gas tightness test	Yes
Equipotential bonding satisfactory	Yes

This safety record is issued by: Signed

Printed name Chris Roberts

Received by: Mike Taylor

Date: 25-Aug-2026

Certificate Expiry 25-08-2027